



- ① 2" conduit - L821 control conduit (Hanger)
- ② 1-3" Power Feed
 - 2-2" Empty/spare stubbed out of vault
 - 1-1" Grounding
 - 1-1" Empty/spare stubbed out of vault
- ③ 1-2" Data conduit (Hanger)
 - 1-1" Photocell
 - 1-1" Antenna
 - 1-1" Exterior Light
- ④ 1-2" Beacon
 - 1-2" spare stubbed out of vault
 - 1-2" wind cone
 - 1-2" Set A Fuel

- ⑤ 4-2" all fiber stubbed out of vault
- ⑥ 1-2" Runway 18/36
 - 1-2" Runway 13/31
 - 2-2" spare stubbed out of vault

HUFSCUTT
CONCRETE, INC.
1414 13th Street
Chapman Park, WI 53519
Ph: 715/232-3444
www.hufscutt.com

BETON-STAHLLING
BETON-STAHLLING, Inc.
Madison, WI 53704
1875 Wilson Avenue, Suite 208
Madison, WI 53713
Ph: 608/264-8113
www.Beton-Stahl.com

PROJECT CONTACTS
PROJECT MANAGER
KYLE SCHROEDER
PROJECT SUPERVISOR
TIMOTHY W. HARRIS
PROJECT SUPERVISOR
TIMOTHY W. HARRIS
PROJECT SUPERVISOR
TIMOTHY W. HARRIS
PROJECT SUPERVISOR
TIMOTHY W. HARRIS
PROJECT SUPERVISOR
TIMOTHY W. HARRIS

DATE: 10/26/20
FOR APPROVAL

1	
2	
3	
4	
5	

PROJECT NUMBER: 17B-054-20

PROJECT: MARSHALLTOWN MUNICIPAL AIRPORT VAULT

DATE PLOT: 10/26/20
PROJECT: MARSHALLTOWN MUNICIPAL AIRPORT VAULT
DRAWING: PLANS, ELEVATIONS, & DETAILS
SCALE: 1.01